



Sacramento Metropolitan Fire District

Community Risk Reduction Division

www.metrofire.ca.gov

10545 Armstrong Ave., Suite 310 · Mather, CA 95655 · Phone (916) 859-4330 · Fax (916) 859-3717

FLOOR SURFACING & FINISHING CHECKLIST

California Fire Code Chapter 24 Section 2410

Scope

An operational permit is required for floor surfacing and finishing operations exceeding 350 ft² and using Class I or II liquids.

Conditions:

- Heating, ventilation and air conditioning systems are not operated during or within 4 hours of resurfacing or refinishing operations. (CFC 2410.1)
- Floor resurfacing or refinishing operations are not conducted while open to the public. (CFC 2410.3)
- All electrical sources of ignition are shut down within flammable vapor area during or within 4 hours of resurfacing or refinishing operations. (CFC 2410.2)
- 1cfm per square foot temporary ventilation to exterior is provided. (CFC 2410.5)

Additional Requirements may apply.