



KURT P. HENKE
Fire Chief

Sacramento Metropolitan Fire District

Community Risk Reduction Division

3012 Gold Canal Drive · Rancho Cordova, CA 95670 · Phone (916) 859-4330 · Fax (916) 859-3717

LIQUID OR GAS-FUELED VEHICLES IN AN ASSEMBLY CHECKLIST

California Fire Code Chapter 3

Scope

An operational permit is required to display, operate or demonstrate liquid or gas fueled vehicles or equipment in assembly buildings.

Conditions:

- Fixtures and displays of goods for sale are arranged to maintain free, immediate and unobstructed access to exits.
- Indoor displays of highly combustible goods, including but not limited to fireworks, flammable or combustible liquids, liquefied flammable gases, oxidizing materials, pyroxylin plastics and agricultural goods are located 5 feet or more from entrances to exits and exterior exit doors.
- Batteries in vehicles for display are disconnected.
- Fuel in vehicles for display does not exceed one-quarter tank or 5 gallons (whichever is less).
- Display vehicle fuel tanks and fill openings are closed and sealed to prevent tampering.
- Vehicles, boats or other motorcraft equipment are not fueled or defueled in the building.

Additional Requirements may apply