



KURT P. HENKE
Fire Chief

Sacramento Metropolitan Fire District

Community Risk Reduction Division

3012 Gold Canal Drive · Rancho Cordova, CA 95670 · Phone (916) 859-4330 · Fax (916) 859-3717

AEROSOLS CHECKLIST

California Fire Code Chapter 28

An operational permit is required to manufacture, store or handle an aggregate quantity of Level 2 or Level 3 aerosol products in excess of 500 pounds net weight.

Inside Storage

Storage of Level 2 and 3 aerosols in occupancy groups A, B, E, F, I, and R shall not exceed the following maximum quantities.

- Level 2 net weight does not exceed 1,000 lbs.
- Level 3 net weight does not exceed 500 lbs.
- Level 2/3 combined net weight does not exceed 1,000 lbs.

Display for Retail

1. Aerosol products in retail display areas shall not exceed the following quantities.
 - Basement – Protected area - does not exceed 500 lbs.
 - Ground Floor – Unprotected area – does not exceed 2,500 lbs.
 - Ground Floor – Protected area (less than 8 feet high) - does not exceed 10,000 lbs.
 - Upper Floor – Unprotected area – does not exceed 2,500 lbs.
 - Upper Floor – Protected are (less than 8 feet high) – does not exceed 2,000 lbs.
2. Level 2 and 3 aerosols
 - Are not stacked more than 6 feet high from the base of the aerosol array to the top of the aerosol array.
 - On shelves to the top of the container, do not exceed 8 feet.
 - Individual cans are not stored above 8 feet high.
 - MSDS information is kept on the premises at an approved location.

Additional requirements may apply